



Product Service

Attestation of Conformity

No. N8A 004172 0009 Rev. 03

Holder of Certificate: **Jinneng Clean Energy Technology Ltd.**
No.1 Wenshui Economic
Development Zone
032100 Lvliang City, Shanxi Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-crystalline Silicon Photovoltaic (PV) Modules

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 882162010603

Date, 2022-06-17


(Xinlian LUO)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 004172 0009 Rev. 03

Model(s):

- With 166mm 1/2 cut mono C-Si solar cell:
- JNMM144-xxx (xxx=425-455, in steps of 5)
- JNMM120-xxx (xxx=355-380, in steps of 5)
- With 158.75mm 1/2 cut mono C-Si solar cell:
- JNMM144-xxx (xxx=375-410, in steps of 5)
- JNMM120-xxx (xxx=315-340, in steps of 5)
- With 182mm 1/2 cut mono C-Si solar cell:
- JNMM144-xxx (xxx=520-555, in steps of 5)
- JNMM132-xxx (xxx=480-505, in steps of 5)
- JNMM120-xxx (xxx=435-460, in steps of 5)
- JNMM108-xxx (xxx=390-415, in steps of 5)
- JNMM96-xxx (xxx=350-365, in steps of 5)
- With 210mm 1/2 cut mono C-Si solar cell:
- JNMM132-xxx (xxx=630-675, in steps of 5)
- JNMM120-xxx (xxx=575-610, in steps of 5)

xxx is standing for rated output power at STC

Parameters:

Safety Class: Class II
 Max. System Voltage: 1500V DC
 Fire Safety Class: Class C according to UL790
 Test Laboratory: Yangzhou Opto-electrical product testing institute
 (10 Kaifa West Rd., Yangzhou, Jiangsu, P. R. China 225009)
 Construction: Framed, with Junction box, cable and connector

Tested according to:

- EN IEC 61730-1:2018
- EN IEC 61730-2:2018
- EN IEC 61730-1:2018/AC:2018-06
- EN IEC 61730-2:2018/AC:2018-06